



ASTA TYPE CERTIFICATE

VERIFICATION OF TEST

Project No: S230003 **Certificate No:** ASTA-TYPE-0002114R1

Applicant: Vietpower Switchboard Manufacture Corporation
R10, Ground floor, Topaz Twins Building, No. 1 Street Area 7,
Thong Nhat Wards, Bien Hoa City, Dong Nai Province, Vietnam

Apparatus: 5000A, 415V/690V/1000V/12kV ($U_e/U_n/U_i/U_{imp}$), 50Hz, IP43, Form 4b
Power Switchgear and Controlgear Assembly (PSC-Assembly) incorporating
three-phase with neutral bare copper conductor main busbar.
One incoming ACB distribution circuit, one outgoing ACB circuit and a
protective earth busbar circuit.
The PSC-Assembly is suitable for indoor application, natural air ventilation
with top hat covering chimney, and has a metallic enclosure.

Manufactured By: Vietpower Switchboard Manufacture Corporation
79, Group 6, Tan Lap Quarter, Phuoc Tan Ward, Bien Hoa City,
Dong Nai Province, Vietnam

Test Report No: YDY22-001385/YDY21-00673

Designation: VSM-5000A

The apparatus which is representative of the designation, supplied drawings and photographs has been evaluated in accordance with:

IEC 61439-2: Edition 3.0 2020-07

Verifications with reference to the tests listed in Annex D of IEC 61439-1: Edition 3.0 2020-05

1: Strength of material and parts	6/7/8: No verification by testing required
2: Degree of protection of enclosures	9: Dielectric properties
3: Clearances	10: Temperature-rise limits
4: Creepage distances	11: Short circuit withstand strength
5: Protection against electric shock and integrity of protective circuits	12: Electromagnetic compatibility (EMC)

The results are shown in the record of tests attached hereto. The values obtained and the general performance is considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated on the ratings page(s) of this Certificate. This Certificate applies only to the apparatus tested. Responsibility for conformity of any apparatus having the same or other designations rests with the Manufacturer.



0010

Punith

Punith Lingamurthy
Certification Engineer

David

David Sim
Certification Officer

26 October 2023

Date