

CÔNG TY
CỔ PHẦN
SẢN XUẤT TỦ ĐIỆN
VIETPOWER

ASTA TYPE CERTIFICATE

ERIFICATION OF TEST

Project No: 230002 Certificate No: ASTA-TYPE-0002113R1

Applicant: Vietpower Switchboard Manufacture Corporation

R10, Ground floor, Topaz Twins Building, No. 1 Street Area 7, Thong Nhat Wards, Bien Hoa City, Dong Nai Province, Vietnam

Apparatus: 4000A, 415V/690V/1000V/12kV (U_e/U_n/U_i/U_{imp}), 50Hz, IP43, Form 4b

Power Switchgear and Controlgear Assembly (PSC-Assembly) incorporating

three-phase with neutral bare copper conductor main busbar.

One incoming ACB distribution circuit, one outgoing ACB circuit and a

protective earth busbar circuit

The PSC-Assembly is suitable for indoor application, natural air ventilation

with top hat covering chimney, and has a metallic enclosure.

Manufactured By: Vietpower Switchboard Manufacture Corporation

79, Group 6, Tan Lap Quarter, Phuoc Tan Ward, Bien Hoa City,

Dong Nai Province, Vietnam

Test Report No: YDY22-001571/YDY21-00673/YDY22-001385

Designation: VSM-4000A

The apparatus which is representative of the designation, supplied drawings and photographs has been evaluated in accordance with:

IEC 61439-2: Edition 3.0 2020-07

Verifications with reference to the tests listed in Annex D of IEC 61439-1: Edition 3.0 2020-05

1:	Strength of material and parts	6/7/8:	No verification by testing required
2:	Degree of protection of enclosures	9:	Dielectric properties
3:	Clearances	10:	Temperature-rise limits
4:	Creepage distances	11:	Short circuit withstand strength
5:	Protection against electric shock and integrity of protective circuits	12:	Electromagnetic compatibility (EMC)

The results are shown in the record of tests attached hereto. The values obtained and the general performance is considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated on the ratings page(s) of this Certificate. This Certificate applies only to the apparatus tested. Responsibility for conformity of any apparatus having the same or other designations rests with the Manufacturer.



faigh.c

Punith Lingamurthy Certification Engineer

li i

David Sim Certification Officer

26 October 2023

Date

schusive use of Intertek's chent and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the erms and to use of this preement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by a use of this preement. Intertek have an one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek issued by Intertek Testing & Certification Ltd., Academy Place, 1-9. Brook Street, Brentwood CM14-5NQ, United Kingdom a UKAS accredited certification body, No. 0010

ntertek

Page 1 of 6

TF-ASTATYPE-02 01-11-2022