



ASTA TYPE CERTIFICATE

OF TEST

Project No:

S230024

Certificate No: ASTA-TYPE-0001824

Applicant:

VietPower Switchboard Manufacture Corporation
R10, Ground floor, Topaz Twins Building, No. 1 Street Area 7,
Thong Nhat Wards, Bien Hoa City, Dong Nai Province, Vietnam

Apparatus:

1250A, 690V/415V/1000V; 750V/12kV; 8kV ($U_n/U_e/U_i/U_{imp}$), 50Hz, IP43, Form 4b
Power Switchgear and Controlgear Assembly (PSC-Assembly) incorporating
three-phase with neutral tinned plate copper conductor main busbars. One
incoming ACB distribution circuit, one vertical zone busbars circuit, one outgoing
MCCB circuit and a protective earth busbar circuit.

The PSC-Assembly is suitable for indoor use and has a metallic enclosure with
one lockable swing door access to ACB. At the top are cap covering chimneys for
natural air ventilation.

Manufactured By:

VietPower Switchboard Manufacture Corporation
79, Group 6, Tan Lap Quarter, Phuoc Tan Ward, Bien Hoa City,
Dong Nai Province, Vietnam

Test Report No:

YDY23-000231/YDY21-00673/YDY22-001430

Designation:

VSM-1250A

The apparatus which is representative of the designation, supplied drawings and photographs has been
evaluated in accordance with:

IEC 61439-2: Edition 3.0 2020-07

Verifications with reference to the tests listed in Annex D of IEC 61439-1: Edition 3.0 2020-05

1: Strength of material and parts	6/7/8: No verification by testing required
2: Degree of protection of enclosures	9: Dielectric properties
3: Clearances	10: Temperature-rise limits
4: Creepage distances	11: Short circuit withstand strength
5: Protection against electric shock and integrity of protective circuits	12: Electromagnetic compatibility (EMC)

The results are shown in the record of tests attached hereto. The values obtained and the general performance
is considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as
stated on the ratings page(s) of this Certificate. This Certificate applies only to the apparatus tested.
Responsibility for conformity of any apparatus having the same or other designations rests with the
manufacturer.



0010

Punith

Punith Lingamurthy
Certification Engineer

li

David Sim
Certification Officer

14 September 2023

Date