



ASTA TYPE CERTIFICATE

VERIFICATION OF TEST

Project No: 104869858LCS002 **Certificate No:** ASTA-TYPE-0001577R1

Applicant: VietPower Switchboard Manufacture Corporation
R10, Ground Floor, Topaz Twins Building, No. 1 Street, Quarter 7, Thong Nhat Ward,
Bien Hoa City, Dong Nai Province, Vietnam.

Apparatus: 3200A, 690/415V/1000V/12kV ($U_n/U_e/U_{imp}$), 50Hz, IP43, Form 4b, power switchgear and controlgear (PSC) assembly incorporating a three-phase and neutral bare copper busbar system. An incoming ACB distribution circuit and a protective earth busbar at bottom. The assembly is cooled by natural ventilation.
The PSC assembly has a fabricated sheet steel enclosure and is suitable for indoor use.

Manufactured By: VietPower Switchboard Manufacture Corporation
79, Group 6, Tan Lap Quarter, Phuoc Tan Ward, Bien Hoa City, Dong Nai Province,
Vietnam.

Test Report No: YDY21000672 / YDY21000673

Designation: MSB 3200A

The apparatus which is representative of the designation, supplied drawings and photographs has been evaluated in accordance with:

IEC 61439-2: Edition 3.0, 2020-07, clauses 10.2 to 10.5 and 10.9 to 10.12

Verifications with reference to the tests listed in Annex D of IEC 61439-1: Edition 3.0, 2020-05

1: Strength of material and parts	6/7/8: No verification by testing required
2: Degree of protection of enclosures	9: Dielectric properties
3: Clearances	10: Temperature-rise limits
4: Creepage distances	11: Short-circuit withstand strength
5: Protection against electric shock and integrity of protective circuits	12: Electromagnetic compatibility (EMC)

The results are shown in the record of tests attached hereto. The values obtained and the general performance is considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated on the ratings page(s) of this Certificate. This Certificate applies only to the apparatus tested. Responsibility for conformity of any apparatus having the same or other designations rests with the Manufacturer.



A. Majid
R. W. Hayward

A Majid
Certification Engineer

R W Hayward
Certification Officer

25th October 2023

Date

This Certificate is for the exclusive use of the Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek shall not be liable to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Any use of the Intertek logo or its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Issued by Intertek (UK) Ltd., Academy Place, 1-9 Brook Street, Brentwood CM14 5NQ, United Kingdom
This Certificate is issued under UKAS Accreditation No 0010 and the outcome falls within the bounds of flexible scope accreditation.